Digitally signed by:
MiEnviro Portal
Date: 2026.04.28 14:56:11 -04:00
Reason: Submission Data
Location: State of Michigan

Report of Discharge (CSO/SSO/RTB)

version 1.15

(Submission #: HQM-SKJ7-J29PK, version 5)

Details

Submission ID HQM-SKJ7-J29PK

Form Input

Report Details

Is this the inital or final discharge report?
Final

Site/Facility Name:
Bellaire WWTP

Permit Number (if applicable):
MI0044873

Sewer System or Treatment Facility Owner

Organization Name
Village of Bellaire

Phone Type	Number	Extension
Business	2315338213	

Email
NONE PROVIDED

Fax
NONE PROVIDED

Address
202 North Bridge Street
PO Box 557
Bellaire, MI 49615
United States

Facility Address
505 South Court Street
Bellaire, MI 49615

Sewer System or Treatment Facility Owner Location
44.9697,-85.2081

505 South Court Street, Bellaire, MI

Discharge Details (1 of 1)

Other Discharge from Lagoon #2 overflowing to surrounding land `OUTFL_ID_TXT`

Discharge Type:
Other Discharge
What type of discharge?
Lagoon overflowing due to limited freeboard

Other Discharge

The reported discharge was of untreated or partially treated sewage (definition in Section 3112a) which is not characterized by RTB, CSO, or SSO Discharges.

Is the outfall or discharge area located at a private residential address?
NO

Outfall or Discharge Area Name
Lagoon #2 overflowing to surrounding land

Outfall or Discharge Area Description
Land surrounding lagoon #2 in bellaire

Outfall or Discharge Area Location
44.96831,-85.20878

Has the discharge ended?
YES

Volume Discharged	Unit	Was the volume estimated?
10557000	Gallons	Yes

Quality of Discharge
Partially Treated

Please describe the discharge, including the reason for Discharge
Due to recent heavy rainfall and snowmelt, lagoon levels have been extremely high. Lagoon #2 found to be overflowing to nearby land/swamp on morning of 4/13. Valve between lagoon #2 and #3 is open. Began actively discharging from lagoon 3 via a pump to decrease lagoon levels. Pump was shut off once desired freeboard levels were reached on 4/20.

Were all effluent limits met during the event?
NO
Explain which effluent limits were not met
Discharge was only partially treated and was not disinfected

Was the land or surface water impacted by the discharge?
Both land and water impacted

Name of Surface Water(s) Impacted:
Intermediate River

Name/description of the land impacted:
Land/swamp in proximity to lagoon

Discharge Event Start

Date	Time
04/13/2026	08:00 am

Discharge Event End

Date	Time
04/20/2026	03:00 pm

Name of the wastewater treatment facility that normally receives sewage.
Bellaire WWTP

Was the reported discharge caused by a party other than the sewer system owner and out of the control or knowledge of the actions which resulted in the discharge?
NO

Is the sewer system owner in compliance with applicable discharge permits, laws, rules, and orders?
NO

Explain why the sewer system owner is not in compliance.
Freeboard on lagoons was not at or below the required minimum of 2 ft of freeboard which contributed to the overflow.

Initial Notification

Organization	Date	Time
Local Health Department	04/24/2026	02:46 pm
Daily Local Newspaper	04/25/2026	06:45 am

Was EGLE notified prior to this report being received?
EGLE was notified prior to this report being submitted

Prior EGLE notification that discharge has started

EGLE Notification Method	Person(s) notified	EGLE Notification Date	EGLE Notification Time	Comments
Phone	Claire Lowe	04/13/2026	02:12 pm	*NONE PROVIDED*

Email notification is only acceptable for CSO/RTB discharges and those discharges that have an alternative notification method previously approved by the Department

Notification that discharge has concluded.

Organization	Date	Time
Local Health Department	04/24/2026	02:46 pm
Daily Local Newspaper	04/25/2026	06:45 am

Precipitation Type(s) (Select none if there was no precipitation)
Rain

Has the precipitation ended?
YES

Precipitation

Start Date	Start Time
04/12/2026	07:00 am

Precipitation Amount (Inches)	Precipitation End Date	Precipitation End Time
4.5	04/19/2026	12:00 am

Precipitation comments
Ongoing rain off and on throughout the event

Actions taken to minimize the impact from the discharge(s):
The Antrim County Health Department issued a request to the public to limit their water usage to reduce incoming influent.

Actions taken, or that will be taken, to prevent this discharge event from reoccurring:
Investigation is needed to address a suspected I&I problem with the Village of Bellaire.

Was this discharge disinfected to meet fecal coliform limitations?
NO

Results of E. coli testing
Samples Not Taken as Required

Additional Details

Report Submitter

Prefix
NONE PROVIDED

First Name	Last Name
Julie	Caliguri

Title
NONE PROVIDED

Organization Name
Operations Services

Phone Type	Number	Extension
Business	9892173175	

Email
jlafond@operationsservices.com

Fax
NONE PROVIDED

Address
10281 Old US HWY 27 South
Gaylord, MI 49735
[NO COUNTRY SPECIFIED]

Do you have any additional comments or uploads you would like to provide?
NO

Revisions

Revision	Revision Date	Revision By
Revision 1	4/13/2026 4:38 PM	Julie Caliguri
Revision 2	4/14/2026 11:58 AM	Julie Caliguri
Revision 3	4/21/2026 2:21 PM	Julie Caliguri
Revision 4	4/25/2026 6:37 AM	Julie Caliguri
Revision 5	4/27/2026 12:57 PM	Julie Caliguri